

Engineering Construction and Design Standards
Supplement # 13 Log - December 2025

Section	Sub-Section	Item	Description
2.00	2.12	Retaining Walls	<p>Updated Section 2.12 to include retaining wall requirements consistent with Section 13, ensuring the provisions apply to all public utility easements (water, sewer and reclaimed), streets, and stormwater, rather than only force mains.</p> <p>"All retaining walls shall have a separation from the easement boundary of at least 1:1, vertical to horizontal. For example, if the retaining wall is 10-feet tall, it shall be placed no closer than 10-feet from the easement."</p>
4.00	4.03	Temporary Measures M. Slope Drains	Previously referenced detail HS23EC in Section 4.03, was changed to reference current detail HS425.

Revised DETAILS	Name
HS009	Updated bench measurements per bench manufacturers guidelines; Replaced 52" with 4ft in detail title
HS014	New Detail - Greenway Trash and Recycling Cans added to standardize the trash can requirement for consistency.
HS374	Changed 585C from Gold to Green; Removed black circle around Town logo; Removed outlines on sign; Town Logo removed from back view of sign; Color of blue part of sign to match legend C3; provided dimension of bottom part of sign
HS375	Provided dimension of height; corrected sign height to match HS374; Specified brick spacing
HS398	Changed 585C from Gold to Green
HS618	Added additional note to state that all piping shall be brass or copper
HS620	Added additional note to state that all piping shall be brass or copper